

KU LEUVEN



Ontwerp van een (warmtepomp)installatie met betonkernactivering

Maarten Sourbron, KULeuven(De Nayer)
Warmtepomp Symposium
Sint-Katelijne-Waver, 11 september 2013




Content

- Why TABS?
- Three thermal characteristics
- Learning from a case-study
- Controller design
- Conclusions



KU LEUVEN

Thermally Activated Building Systems (TABS) or Concrete Core Activation (CCA)




KU LEUVEN

Why TABS?

- Radiative heating/cooling more comfortable
- Low temperature heating/high temperature cooling
 - Heat pumps, ground cooling, night cooling
- Large thermal mass
 - Heat/cold storage
 - TABS uncouples heat/cold production from heat/cold emission

KU LEUVEN

Controlled input / uncontrolled output




Three thermal characteristics

- Limited steady state thermal power
- Large thermal mass \rightarrow large time constant
- Large thermal power from water to TABS (in transient regime)




Three thermal characteristics

- Uncovered 20 cm concrete slab
- Step change in water supply from 20°C to 30°C




Three thermal characteristics

- Uncovered 20 cm concrete slab
- Step change in water supply from 20°C to 30°C




Limited thermal power - building thermal loads

- TABS with raised floor and heat pump / direct cooling



Large thermal mass

- Step change in water supply from 20°C to 30°C
- Thermal power
- Thermal energy



Large thermal mass: example 1

- 1 cm of reinforced concrete = $6 \text{ Wh/m}^2\text{K}$
 - e.g. increasing a 20 cm concrete slab with 1 K:
 120 Wh/m^2
 - e.g. a K30 building, $U_{\text{mean}} = 0.36 \text{ W/m}^2\text{K}$, 75 m^2 floor area, 20°C indoor, 0°C outdoor:
 670 Wh/m^2 heat loss in 24 h
 - e.g. with 30 W/m^2 available:
 $\sim 4 \text{ h}$ run time for 1 K-increase of 20 cm concrete slab

KU LEUVEN

Large thermal mass: example 2


- Nathan, Duiven (The Netherlands)



KU LEUVEN


Large thermal mass: example 2

- Well designed system, but **unadapted control strategy**




Large thermal mass: example 2

- Compared to 'Only Cooling control strategy'




Large thermal mass: example 2

- Compared to 'Only Cooling control strategy'




Large thermal power from water to TABS




TABS + building: controller design



- Building that fits TABS




- Heating load: **26 W/m²**
- Cooling load: **25 W/m²** (office hours average)

KU LEUVEN






TABS + building: Rule based control



TABS + building: Rule based control





No heating and cooling of TABS during 1 day


KU LEUVEN

TABS + building: Rule based control

- Best results: keep TABS at temperature
 - $T_{\text{controlled}} = T_{\text{ceiling}}$
 - Heating on: $T_{\text{comfort,min}}$
 - Cooling on: $T_{\text{comfort,max}} - 2^\circ\text{C}$
 - Heating/cooling curve: $+3^\circ\text{C}/-3^\circ\text{C}$
 - No night setback




Rule based feedback control




TABS + building: Rule based control

- Alternating zone operation




TABS + building: MPC


- Optimal use of thermal inertia
- Combination of TABS and fast reacting system:
 - Air Handling Unit
- Possible solution with MPC (Model based Predictive Control)



TABS + building: MPC



MPC description



MPC description: optimal control problem

$H_c = 24h$
 $H_p = 48h$

TABS $E_{prim.}$
 Heating+Cooling

AHU $E_{prim.}$
 Heating+Cooling

$$\min_{T_{ws}, T_{vs}} \sum_{k=0}^{H_p} ([J_{ew,h}(k) + J_{ew,c}(k) + J_{ev,h}(k) + J_{ev,c}(k)] F_1 \dots$$

$$\dots + [\alpha_{du} J_{du}(k) + \alpha_{do} J_{do}(k)] (1 - F_1) F_2 \Delta t_c$$


Thermal discomfort
Under+Over


\swarrow 1h

Constraints:


- 2nd order building model
- Initial temperatures ('measured')
- Limited T_{ws} and T_{vs}
- Limited thermal production power

Tuning:





Results: heating control comparison



Results: heating control comparison

Rule Based
(C⁴)

Model Based
(MPC)


Controller	$E_{\text{TAHS,prim}}$ (kWh/m ²)	$E_{\text{AHU,prim}}$ (kWh/m ²)	$E_{\text{TOT,prim}}$ (kWh/m ²)	DC (Kh)
C ⁴	0.20	0.06	0.25	0.02
MPC	0.38	0.06	0.43	0.00

KU LEUVEN

Results: cooling control comparison

Rule Based
(C⁴)

Model Based
(MPC)



KU LEUVEN

Results: cooling control comparison

Rule Based
(C⁴)

Model Based
(MPC)

Controller	$E_{\text{TABS,prim}}$ (kWh/m ²)	$E_{\text{AHU,prim}}$ (kWh/m ²)	$E_{\text{TOT,prim}}$ (kWh/m ²)	DC (Kh)
C ⁴	0.12	0.01	0.13	0.81
MPC	0.00	0.01	0.01	1.59

KU LEUVEN

Conclusions: TABS important features

- Limited thermal power
- Slow reacting system
- High start-up thermal power
- (CCA requires) a high quality building
- Allow temperature drift in the building zone
- No individual zone control

KU LEUVEN

Conclusions: rule based control

- Control strategy determines size of production system
- No heating/cooling switching in 1 day
- Rule based control: $T_{\text{TABS}} = T_{\text{comfort,min}} + 1^{\circ}\text{C}$
- No feedback on zone temperature
- Alternating zone operation to reduce production power



KU LEUVEN

Conclusions: MPC

- Good candidate for integrated control
- Controlling CCA + fast system (AHU)
- Sensitive to errors
 - Model
 - Predictions
 - Measurements
 - Cost function



KU LEUVEN



KATHOLIEKE UNIVERSITEIT
LEUVEN



Thank you